

Particle Counts

(Measured at 0.5 microns and larger)
Cleanroom

2	0	8	5	3	4	0	5	0
7	1	15	3	1	2	0	7	1
6	2	7	0	0	4	4	1	9
4	2	10	0	0	1	1	3	4
0	0	3	11	3	2	1	4	6
6	3	4	7	4	4	1	7	11
1	8	3	6	5	8	1	3	3
2	4	8	2	1	0	3	5	0

NOTE: For our clients considering ISO 14644-1 for Air Cleanliness Classification, a comparison is provided.

Lgth Wdth
 Dimensions 33.5 18.5
 Area(Sq. Ft.) 620
 Target Class 100

AT .5 MICRONS AND LARGER				
# of	95%			
Locations	High	Avg.	UCL	Class
72	15	4	N/A	100

ISO 14644-1	
Area (Sq. M.)	57.6
Req. Locations	OK
ISO Class	5

ENV Services, Inc. <i>Service Specialists for Contamination Control</i>	Project: White Knight Fluid Handlers, Inc. Hemlock, MI 48626
11550 IH 10 West, Suite 260 San Antonio, TX 78230	(800) 690-3368 Test Date: August 9, 2000
Technician: ME	Prepared by: deb Approval: CENV200009007-09/16