

Particle Counts

(Measured at 0.5 microns and larger)
Gowning Room

162	181	183
147	98	118
153	131	173

NOTE: For our clients considering ISO 14644-1 for Air Cleanliness Classification, a comparison is provided.

Lgth Wdth
 Dimensions 9.5 15.75
 Area(Sq. Ft.) 150
 Target Class **1,000**

AT .5 MICRONS AND LARGER				
# of	95%			
Locations	High	Avg.	UCL	Class
9	183	150	168	1,000

ISO 14644-1
Area (Sq. M.) 13.9
Req. Locations OK
ISO Class 6

ENV Services, Inc. <i>Service Specialists for Contamination Control</i>	Project: White Knight Fluid Handlers, Inc. Hemlock, MI 48626
11550 IH 10 West, Suite 260 San Antonio, TX 78230	(800) 690-3368 Test Date: August 9, 2000
Technician: ME	Prepared by: deb Approval: <i>CENV200009007-10/16</i>